

| HEATER TYPE | kW | 'A' | 'B' | 'C' | 'D' | 'E' |
|-------------|-----|------|-----|-----|-----|------|
| EHL 11 | 30 | 1100 | 356 | 520 | 15 | 915 |
| EHL 12 | 36 | 1500 | 356 | 520 | 15 | 1220 |
| EHL 13 | 48 | 1500 | 356 | 520 | 15 | 1370 |
| EHL 14 | 60 | 2000 | 356 | 520 | 15 | 1830 |
| EHL 15 | 72 | 2000 | 356 | 520 | 18 | 1830 |
| EHL 16 | 84 | 2000 | 406 | 580 | 18 | 1830 |
| EHL 17 | 96 | 2500 | 406 | 580 | 18 | 2440 |
| EHL 18 | 108 | 2500 | 406 | 580 | 18 | 2440 |
| EHL 19 | 120 | 2500 | 457 | 640 | 24 | 2440 |
| EHL 20 | 144 | 2500 | 457 | 640 | 24 | 2440 |

WHEN USING ELECTRONIC CONTROLLER
THERMOMETER CONNECTION IS DELETED
THERMOSTAT POCKETS REMAIN AS
STANDARD
NOTE - THIS RANGE UNDER REVISION.
PLEASE ENQUIRE FOR LATEST VERSION.


SUPERSEDES ALL PREVIOUS ISSUES

DESIGN DETAILS

HYDRAULIC TEST PRESSURE : 24 bar.g.
OIL WORKING PRESSURE : 16 bar.g.

GENERAL

FINISH : CLADDING PRIMED & PAINTED MAYFAIR BLUE
ALL MATERIALS MILD STEEL UNLESS OTHERWISE STATED
DIMENSIONS IN 'mm' UNLESS OTHERWISE STATED
DUE TO INDIVIDUAL REQUIREMENTS SOME DETAILS MAY DIFFER

| | | | | | | | | |
|-------|--|-------|--|-------|--------------------------------|-----------------------------------------------------------------------------------------------------------------------------------------------------------|-------------|-----------------------------------------------------------|
| Rev F | | Rev D | | Rev B | CORRECTED TYPOS IN TABLE |  A.K. WAUGH LIMITED 49 DALSETTER AVENUE, GLASGOW, G15 8TE. | DRAWN | A. WAUGH |
| Rev E | | Rev C | | Rev A | ELECTRONIC CONTROL NOTES ADDED | | TITLE | GENERAL DETAILS OF 'EHL' TYPE ELECTRIC IN-LINE HEATERS |
| | | | | | | | DATE | 25/08/09 |
| | | | | | | | SCALE | N/A |
| | | | | | | | DRAWING No. | EHL-GEN-09 |
| | | | | | | | REVISION | 0 X X |